



Baytown Fire Marshal's Office

Basic Fire/Life Safety Inspection Checklist

International Fire Code 2006 ed.

8/09

Date:		Business Name:		Permit #:	
Business Phone:		Business Address:		Contact :	
Gas Leak Test: <input type="checkbox"/> Current <input type="checkbox"/> Expired <input type="checkbox"/> None <input type="checkbox"/> Not Accessible	Kitchen Suppression System: <input type="checkbox"/> Current <input type="checkbox"/> Expired <input type="checkbox"/> None <input type="checkbox"/> Not Accessible	Fire Alarm System: <input type="checkbox"/> Current <input type="checkbox"/> Expired <input type="checkbox"/> None <input type="checkbox"/> Not Accessible	Fire Sprinkler System: <input type="checkbox"/> Current <input type="checkbox"/> Expired <input type="checkbox"/> None <input type="checkbox"/> Not Accessible	Portable Fire Extinguishers: <input type="checkbox"/> Current <input type="checkbox"/> Expired <input type="checkbox"/> None <input type="checkbox"/> Not Accessible	
<input type="checkbox"/> General Housekeeping Hazard – 304.1			<input type="checkbox"/> Fire Extinguishers (minimum of a 2A-10BC rating) Not Maintained in an Operative Condition - 906.2		
<input type="checkbox"/> Vacant Premises Must Be Safeguarded – 311.2			<input type="checkbox"/> Fire Extinguisher Blocked / Inaccessible – 906.6		
<input type="checkbox"/> Lint/Combustibles in Laundry Dryer Area – 305.1			<input type="checkbox"/> Fire Extinguisher Mounted Higher than 5 Feet above the Floor - 906.9		
<input type="checkbox"/> Combustible storage must be no higher than 24 Inches Below Ceiling (non-sprinklered) – 315.2.1			<input type="checkbox"/> Access Not Available to Fire Department Connection – 912.3		
<input type="checkbox"/> Combustible storage must be no higher than 18 Inches Below Sprinkler Heads – 315.2.1			<input type="checkbox"/> Fire Department Connection Not Labeled – 912.2.2 & 912.4		
<input type="checkbox"/> No combustible Material may be stored In Electrical, Boiler or Mechanical Room – 315.2.3			<input type="checkbox"/> Means of Egress (Exit corridors) Obstructed (Reduced or Blocked) – 1003.6		
<input type="checkbox"/> Fire Apparatus Access Obstructed (Vehicles Parked in Fire Lane) – 503.4 <input type="checkbox"/> Fire lane needs to be properly marked / painted.			<input type="checkbox"/> Emergency Egress Lighting Not Installed or Needs Repair - 1006		
<input type="checkbox"/> Address Not Visible From Street (Minimum Size 4 Inches) – 505.1			<input type="checkbox"/> Doors Do Not Swing in the Direction of Egress – 1008.1.2		
<input type="checkbox"/> Fire Department Hindered From Gaining Access to Fire Protection Equipment or Fire Hydrant – 508.5.4			<input type="checkbox"/> Are Exit Doors Locked – 1008.1.8		
<input type="checkbox"/> Rooms That Contain Air Conditioning Controls Fire Alarms, Fire Sprinkler Equipment Not Labeled– 510.1			<input type="checkbox"/> Additional Locks Installed On Exit Doors – 1008.1.8.4		
<input type="checkbox"/> Fuel-Fired Appliances Not in Accordance With Mechanical Code or Manufacturers Instructions - 603			<input type="checkbox"/> Panic and Fire Exit Hardware Not Maintained – 1008.1.9		
<input type="checkbox"/> Electrical Wiring Not in Accordance With Electrical Code - 605			<input type="checkbox"/> Exit Signs Not Installed or Needs Repair - 1011		
<input type="checkbox"/> No Extension Cords Used in Place of Permanent Wiring – 605.5			<input type="checkbox"/> Spray Booth Not Installed or Protected to meet the requirements per Chapter 15		
<input type="checkbox"/> Covers Not Provided for Electrical Breakers / Junction Boxes - 605.6			<input type="checkbox"/> Compressed Gas Cylinders not Secured from Falling – 3003.3.3		
<input type="checkbox"/> Covers Not Provided for Electrical Switches / Outlets – 605.6			<input type="checkbox"/> Storage Cabinet Not Provided for Storage of Flammable Liquids -3404.3.2		
<input type="checkbox"/> Penetrations Not Sealed in Floors / Walls / Ceilings (Repair or Replace Missing Ceiling Tiles) – 703.1			<input type="checkbox"/> Additional IFC 2006 Deficiencies		
<input type="checkbox"/> Excessive Combustible Items Hanging From Ceiling - 805			Comments:		
<input type="checkbox"/> Fire Suppression (Cooking Equip.) Not Maintained in an Operative Condition – 901.6					
<input type="checkbox"/> Excessive Amount of Grease on Cooking Equipment /Hood - 904.11.6.4					
<input type="checkbox"/> Fire Alarm System Not Maintained in an Operative Condition – 901.6					
<input type="checkbox"/> Fire Sprinkler System Not Maintained in an Operative Condition – 901.6					

